

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River CDC I
 Building No: 2813

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY <small>[Enter water's intended use]</small>	SAMPLE ID	Outlet Description <small>[Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]</small>	Comments <small>[Provide, for example, whether filter was removed, staining was present, any identifying marks]</small>	Lead Screening Level of 15ppb					Description <small>[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]</small>	Recommended Level = 15ppb		
				First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>	Retest required? <small>[Enter YES/NO]</small>	Date Fixture Secured? (See Note 1) <small>[Enter N/A if First Draw is < 20ppb; otherwise enter mm/dd/yyyy]</small>	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	First Draw (ppb) (See note 2) <small>[Enter non-detect/ numeric value]</small>	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/10/2019	
RESULTS DATE				8/12/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/17/2019	
DRINKING	PX-2813-OUT101-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 101--OUTSIDE		1.3	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-OUT105-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 105--OUTSIDE		2.1	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-OUT111-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 111--OUTSIDE		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-OUT116-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 116--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-OUT125-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 125--OUTSIDE		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-PSH140-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 140--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-PSH141-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 141--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-PSH142-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 142--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-PSH143-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 143--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-OUT143-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 143--OUTSIDE		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-PSH144-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 144--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-TOD145-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 145--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-TOD146-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 146--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-TOD147-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 147--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-OUT147-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 147--OUTSIDE		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-TOD148-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 148--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-TOD149-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 149--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-WFC-A-FD	Water Fountain, Hallway High A		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2813-WFC-B-FD	Water Fountain, Hallway Low B		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF101-K-FD	KITCHEN SINK FOR FOOD PREP--, 101--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF102-K-FD	KITCHEN SINK FOR FOOD PREP--, 102--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF103-K-FD	KITCHEN SINK FOR FOOD PREP--, 103--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF104-K-FD	KITCHEN SINK FOR FOOD PREP--, 104--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF104-KSP-FD	KITCHEN SINK SPRAYER--, 104--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF105-K-FD	KITCHEN SINK FOR FOOD PREP--, 105--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF105-KSP-FD	KITCHEN SINK SPRAYER--, 105--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF106-K-FD	KITCHEN SINK FOR FOOD PREP--, 106--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF106-KSP-FD	KITCHEN SINK SPRAYER--, 106--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF110-K-FD	KITCHEN SINK FOR FOOD PREP--, 110--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF110-KSP-FD	KITCHEN SINK SPRAYER--, 110--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF111-K-FD	KITCHEN SINK FOR FOOD PREP--, 111--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF111-KSP-FD	KITCHEN SINK SPRAYER--, 111--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF112-K-FD	KITCHEN SINK FOR FOOD PREP--, 112--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF112-KSP-FD	KITCHEN SINK SPRAYER--, 112--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF113-K-FD	KITCHEN SINK FOR FOOD PREP--, 113--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF113-KSP-FD	KITCHEN SINK SPRAYER--, 113--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PTOD114-K-FD	KITCHEN SINK FOR FOOD PREP--, 114--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF114-KSP-FD	KITCHEN SINK SPRAYER--, 114--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River CDC I
 Building No: 2813

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Outlet Description [Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]	Comments [Provide, for example, whether filter was removed, staining was present, any identifying marks]	Lead Screening Level of 15ppb					Description [Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]	Recommended Level = 15ppb		
				First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter N/A if First Draw is ≤ 20ppb; otherwise enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [See note 2] [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/10/2019	
RESULTS DATE				8/12/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/17/2019	
COOKING	PX-2813-PTOD115-K-FD	KITCHEN SINK FOR FOOD PREP-- ,115--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PTOD115-KSP-FD	KITCHEN SINK SPRAYER-- ,115--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PTOD116-K-FD	KITCHEN SINK FOR FOOD PREP-- ,116--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF116-KSP-FD	KITCHEN SINK SPRAYER-- ,116--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PTOD117-K-FD	KITCHEN SINK FOR FOOD PREP-- ,117--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PTOD117-KSP-FD	KITCHEN SINK SPRAYER-- ,117--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PTOD122-K-FD	KITCHEN SINK FOR FOOD PREP-- ,122--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PTOD122-KSP-FD	KITCHEN SINK SPRAYER-- ,122--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF123-K-FD	KITCHEN SINK FOR FOOD PREP-- ,123--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF123-KSP-FD	KITCHEN SINK SPRAYER-- ,123--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PTOD124-K-FD	KITCHEN SINK FOR FOOD PREP-- ,124--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF124-KSP-FD	KITCHEN SINK SPRAYER-- ,124--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF125-K-FD	KITCHEN SINK FOR FOOD PREP-- ,125--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF125-KSP-FD	KITCHEN SINK SPRAYER-- ,125--Pretoddler Room		1.4	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF127-K-FD	KITCHEN SINK FOR FOOD PREP-- ,127--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF127-KSP-FD	KITCHEN SINK SPRAYER-- ,127--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-TL134-K-FD	KITCHEN SINK FOR FOOD PREP-- ,134--Teacher's Lounge		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-TL134-KSP-FD	KITCHEN SINK SPRAYER-- ,134--Teacher's Lounge		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-HHWA-FD	HIGH HAND WASHING (adults)--A, 137--Kitchen		1.9	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-HHWB-FD	HIGH HAND WASHING (adults)--B, 137--Kitchen		4.1	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-HHWC-FD	HIGH HAND WASHING (adults)--C, 137--Kitchen		2.7	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-KA-FD	KITCHEN SINK FOR FOOD PREP--A, 137--Kitchen		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-KB-FD	KITCHEN SINK FOR FOOD PREP--B, 137--Kitchen		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-KC-FD	KITCHEN SINK FOR FOOD PREP--C, 137--Kitchen		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-KSPA-FD	KITCHEN SPRAYER--A, 137--Kitchen		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-KSPB-FD	KITCHEN SPRAYER--B, 137--Kitchen		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-K137-P100710-FD	FOOD PREP POT SINK (P100710)-- ,137--Kitchen		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH140-K-FD	KITCHEN SINK FOR FOOD PREP-- ,140--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH140-KSP-FD	KITCHEN SINK SPRAYER-- ,140--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH141-K-FD	KITCHEN SINK FOR FOOD PREP-- ,141--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH141-KSP-FD	KITCHEN SINK SPRAYER-- ,141--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH142-K-FD	KITCHEN SINK FOR FOOD PREP-- ,142--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH142-KSP-FD	KITCHEN SINK SPRAYER-- ,142--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH143-K-FD	KITCHEN SINK FOR FOOD PREP-- ,143--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH143-KSP-FD	KITCHEN SINK SPRAYER-- ,143--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH144-K-FD	KITCHEN SINK FOR FOOD PREP-- ,144--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH144-KSP-FD	KITCHEN SINK SPRAYER-- ,144--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-TOD145-K-FD	KITCHEN SINK FOR FOOD PREP-- ,145--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River CDC I
 Building No: 2813

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Outlet Description [Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]	Comments [Provide, for example, whether filter was removed, staining was present, any identifying marks]	Lead Screening Level of 15ppb					Description [Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]	Recommended Level = 15ppb		
				First Draw (ppb) [Enter non-detect/ numeric value]	Retest required? [Enter YES/NO]	Date Fixture Secured? (See Note 1) [Enter N/A if First Draw is ≤ 20ppb; otherwise enter mm/dd/yyyy]	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]	First Draw (ppb) [Enter non-detect/ numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [Enter non-detect/ numeric value]
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/10/2019	
RESULTS DATE				8/12/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/17/2019	
COOKING	PX-2813-PSH145-KSP-FD	KITCHEN SINK SPRAYER-, 145--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-TOD146-K-FD	KITCHEN SINK FOR FOOD PREP-, 146--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH146-KSP-FD	KITCHEN SINK SPRAYER-, 146--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-TOD147-K-FD	KITCHEN SINK FOR FOOD PREP-, 147--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH147-KSP-FD	KITCHEN SINK SPRAYER-, 147--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-TOD148-K-FD	KITCHEN SINK FOR FOOD PREP-, 148--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH148-KSP-FD	KITCHEN SINK SPRAYER-, 148--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-TOD149-K-FD	KITCHEN SINK FOR FOOD PREP-, 149--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-PSH149-KSP-FD	KITCHEN SINK SPRAYER-, 149--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF101-KSP-FD	KITCHEN SINK FOR FOOD PREP--SPRAY, 101--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF102-KSP-FD	KITCHEN SINK FOR FOOD PREP--SPRAY, 102--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2813-INF103-KSP-FD	KITCHEN SINK FOR FOOD PREP--SPRAY, 103--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF101-HHW-FD	HIGH HAND WASHING (adults)-, 101--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF102-HHW-FD	HIGH HAND WASHING (adults)-, 102--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF102-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 102--Infant Room		1.7	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF103-HHW-FD	HIGH HAND WASHING (adults)-, 103--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF103-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 103--Infant Room		2.8	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF104-HHW-FD	HIGH HAND WASHING (adults)-, 104--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF105-HHW-FD	HIGH HAND WASHING (adults)-, 105--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF106-HHW-FD	HIGH HAND WASHING (adults)-, 106--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF110-HHW-FD	HIGH HAND WASHING (adults)-, 110--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF111-HHW-FD	HIGH HAND WASHING (adults)-, 111--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF112-HHW-FD	HIGH HAND WASHING (adults)-, 112--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF112-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 112--Infant Room		0.92	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF113-HHW-FD	HIGH HAND WASHING (adults)-, 113--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD114-HHW-FD	HIGH HAND WASHING (adults)-, 114--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD114-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 114--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD115-HHW-FD	HIGH HAND WASHING (adults)-, 115--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD115-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 115--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD116-HHW-FD	HIGH HAND WASHING (adults)-, 116--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD116-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 116--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD117-HHW-FD	HIGH HAND WASHING (adults)-, 117--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD117-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 117--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD122-HHW-FD	HIGH HAND WASHING (adults)-, 122--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD122-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 122--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF123-HHW-FD	HIGH HAND WASHING (adults)-, 123--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF123-LHW-FD	LOW HAND WASHING FAUCET (youth)-, 123--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PTOD124-HHW-FD	HIGH HAND WASHING (adults)-, 124--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River CDC I
 Building No: 2813

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY <small>[Enter water's intended use]</small>	SAMPLE ID	Outlet Description <small>[Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]</small>	Comments <small>[Provide, for example, whether filter was removed, staining was present, any identifying marks]</small>	Lead Screening Level of 15ppb					Description <small>[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]</small>	Recommended Level = 15ppb		
				First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>	Retest required? <small>[Enter YES/NO]</small>	Date Fixture Secured? <small>[See Note 1] [Enter N/A if First Draw is ≤ 20ppb; otherwise enter mm/dd/yyyy]</small>	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	First Draw (ppb) <small>[See Note 2] [Enter non-detect/ numeric value]</small>	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/10/2019	
RESULTS DATE				8/12/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/17/2019	
WASHING	PX-2813-PTOD124-LHW-FD	LOW HAND WASHING FAUCET (youth)--, 124--Preschooler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF125-HHW-FD	HIGH HAND WASHING (adults)--, 125--Preschooler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF125-LHW-FD	LOW HAND WASHING FAUCET (youth)--, 125--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF127-HHW-FD	HIGH HAND WASHING (adults)--, 127--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-INF127-LHW-FD	LOW HAND WASHING FAUCET (youth)--, 127--Infant Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-Bath129-HHW-FD	HIGH HAND WASHING (adults)--, 129--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-Bath131-HHW-FD	HIGH HAND WASHING (adults)--, 131--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH140-HHW-FD	HIGH HAND WASHING (adults)--, 140--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH140-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 140--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH140-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 140--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH141-HHW-FD	HIGH HAND WASHING (adults)--, 141--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH141-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 141--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH141-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 141--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH141-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 141--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH142-HHW-FD	HIGH HAND WASHING (adults)--, 142--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH142-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 142--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH142-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 142--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH142-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 142--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH143-HHW-FD	HIGH HAND WASHING (adults)--, 143--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH143-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 143--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH143-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 143--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH143-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 143--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH144-HHW-FD	HIGH HAND WASHING (adults)--, 144--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH144-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 144--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH144-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 144--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH144-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 144--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD145-HHW-FD	HIGH HAND WASHING (adults)--, 145--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD145-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 145--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD145-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 145--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD145-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 145--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD146-HHW-FD	HIGH HAND WASHING (adults)--, 146--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD146-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 146--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD146-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 146--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD146-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 146--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD147-HHW-FD	HIGH HAND WASHING (adults)--, 147--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD147-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 147--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD147-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 147--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD147-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 147--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River CDC I
 Building No: 2813

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Outlet Description	Comments	First Draw (ppb)	Retest required? [Enter YES/NO]	Lead Screening Level of 15ppb Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		Description	Recommended Level = 15ppb First Draw (ppb) (See note 2)
[Enter water's intended use]		[Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]	[Provide, for example, whether filter was removed, staining was present, any identifying marks]	[Enter non-detect/ numeric value]		[Enter N/A if First Draw is ≤ 20ppb; otherwise enter mm/dd/yyyy]	[Enter non-detect/ numeric value]	[Enter non-detect/ numeric value]	[Enter non-detect/ numeric value]	[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]	[Enter non-detect/ numeric value]	[Enter non-detect/ numeric value]
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/10/2019	
RESULTS DATE				8/12/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/17/2019	
WASHING	PX-2813-TOD148-HHW-FD	HIGH HAND WASHING (adults)-, 148--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD148-LHWA-FD	LOW HAND WASHING FAUCET (youth)-A, 148--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD148-LHWB-FD	LOW HAND WASHING FAUCET (youth)-B, 148--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD148-LHWC-FD	LOW HAND WASHING FAUCET (youth)-C, 148--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD149-HHW-FD	HIGH HAND WASHING (adults)-, 149--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD149-LHWA-FD	LOW HAND WASHING FAUCET (youth)-A, 149--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD149-LHWB-FD	LOW HAND WASHING FAUCET (youth)-B, 149--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-TOD149-LHWC-FD	LOW HAND WASHING FAUCET (youth)-C, 149--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-RM130-BTH-HHWA-FD	HIGH HAND WASHING (adults)-A, 130--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-RM132-BTH-HHWA-FD	HIGH HAND WASHING (adults)-B, 132--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-BTHCDC DIR-HHWA-FD	HIGH HAND WASHING (adults)-119-A, CDC DIR--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-BTHCDC DIR-HHWA-FD	HIGH HAND WASHING (adults)-120-B, CDC DIR--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2813-PSH140-LHW-FD	Low Hand Wash F, 140-PreSchool		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Notes:
¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.
² Post-remediation sampling was initially conducted on [ENTER DATE]. Additional [CORRECTIVE ACTIONS DESCRIPTION] were implemented and final results below recommended level of 20ppb for sample collected on [ENTER DATE] are shown on the table.

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River CDC I
 Building No: 2813

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY <small>[Enter water's intended use]</small>	SAMPLE ID	Outlet Description <small>[Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]</small>	Comments <small>[Provide, for example, whether filter was removed, staining was present, any identifying marks]</small>	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description <small>[Enter brief description of remediation activities; for example, replace fixtures, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]</small>	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
				<small>[Enter non-detect/ numeric value]</small>	<small>[Enter YES/NO]</small>	<small>[Enter N/A if First Draw is < 20ppb; otherwise enter mm/dd/yyyy]</small>	<small>[Enter non-detect/ numeric value]</small>	<small>[Enter non-detect/ numeric value]</small>	<small>[Enter non-detect/ numeric value]</small>		<small>[Enter non-detect/ numeric value]</small>	<small>[Enter non-detect/ numeric value]</small>
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/10/2019	
RESULTS DATE				8/12/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/17/2019	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Lead Screening Level of 15ppb						
	First Draw (ppb)		Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)	
Total Drinking	19		0	0	0	0	0
Total Drinking > 15 ppb	0		0	0	0	0	0
Total Cook	69		0	0	0	0	0
Total Cook > 15 ppb	0		0	0	0	0	0
Total Washing	77		0	0	0	0	0
Total Washing > 15 ppb	0		0	0	0	0	0
Total Samples	165		0	0	0	0	0
Total Samples > 15 ppb	0		0	0	0	0	0

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River CDC II
 Building No: 2030

Table 1. Summary of Results												
SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY <small>[Enter water's intended use]</small>	SAMPLE ID	Outlet Description <small>[Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]</small>	Comments <small>[Provide, for example, whether filter was removed, staining was present, any identifying marks]</small>	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	Description <small>[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]</small>	First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
				<small>[Enter non-detect/ numeric value]</small>	<small>[Enter YES/NO]</small>	<small>[Enter N/A if First Draw is ≤ 20ppb; otherwise enter mm/dd/yyyy]</small>	<small>[Enter non-detect/ numeric value]</small>	<small>[Enter non-detect/ numeric value]</small>	<small>[Enter non-detect/ numeric value]</small>		<small>[Enter non-detect/ numeric value]</small>	<small>[Enter non-detect/ numeric value]</small>
SAMPLING DATE				8/3/2019			mm/dd/yyyy			9/10/2019		
RESULTS DATE				8/12/2019			mm/dd/yyyy			9/17/2019		
DRINKING	PX-2030-YARD-WFB-FD	WATER FOUNTAIN (BUBBLER)--, YARD--Hallway		1	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-2030-HLW7-WFB-FD	WATER FOUNTAIN (BUBBLER)--, 7--Hallway		5.1	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2030-K11A-K-FD	KITCHEN SINK FOR FOOD PREP-- , 11A--Kitchen		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2030-INF3-K-FD	KITCHEN SINK FOR FOOD PREP-- , 9--Infant Room		1.2	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2030-INF8-K-FD	KITCHEN SINK FOR FOOD PREP-- , 8--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2030-PTOD8-K-FD	KITCHEN SPRAYER-- , 8--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2030-K11A-KSP-FD	KITCHEN SPRAYER-- , 11A--Kitchen		0.54	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-2030-K11B-HHW-FD	KITCHEN FOOD PREP SINK-- , 11B--Kitchen		1.9	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF9A10A-HHW-FD	HIGH HAND WASHING (adults)-- , 9A/10A--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF9A10A-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 9A/10A--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF9A10A-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 9A/10A--Preschool Room		0.58	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF5A4A-HHW-FD	HIGH HAND WASHING (adults)-- , 5A/4A--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF5A4A-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 5A/4A--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF5A4A-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 5A/4A--Preschool Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF9-HHW-FD	HIGH HAND WASHING (adults)-- , 9--Infant Room		0.91	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF8-HHW-FD	HIGH HAND WASHING (adults)-- , 8--Pretoddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF7-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 7--Toddler Room		1	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF7-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 7--Toddler Room		0.54	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF7-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 7--Toddler Room		0.53	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF6-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 6--Preschool Room		0.6	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF6-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 6--Preschool Room		0.76	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF2440-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 6--Preschool Room		0.8	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF5-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 5--Toddler Room		0.52	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF5-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 5--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF5-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 5--Toddler Room		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-Bath2-HHW-FD	HIGH HAND WASHING (adults)-- , 2--Bathroom Faucets		0.57	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-Bath3-HHW-FD	HIGH HAND WASHING (adults)-- , 3--Bathroom Faucets		1.5	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-BathHLW-HHW-FD	HIGH HAND WASHING (adults)-- , HLW--Bathroom Faucets - Hallway		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF4-LHWA-FD	LOW HAND WASHING FAUCET (youth)--A, 4--Training Room		17.6	Yes	8/12/2019	N/A	N/A	N/A	Replace fixture	2.1	N/A
WASHING	PX-2030-INF4-LHWB-FD	LOW HAND WASHING FAUCET (youth)--B, 4--Infant Room		1	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-2030-INF4-LHWC-FD	LOW HAND WASHING FAUCET (youth)--C, 4--Infant Room		1.2	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Notes:
 1 Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.
 2 Post-remediation sampling was initially conducted on [ENTER DATE]. Additional [CORRECTIVE ACTIONS DESCRIPTION] were implemented and final results below recommended level of 20ppb for sample collected on [ENTER DATE] are shown on the table.

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River CDC II
 Building No: 2030

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY <small>[Enter water's intended use]</small>	SAMPLE ID	Outlet Description <small>[Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]</small>	Comments <small>[Provide, for example, whether filter was removed, staining was present, any identifying marks]</small>	Lead Screening Level of 15ppb								
				First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>	Retest required? <small>[Enter YES/NO]</small>	Date Fixture Secured? <small>(See Note 1)</small> <small>[Enter N/A if First Draw is < 20ppb; otherwise enter mm/dd/yyyy]</small>	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	Description <small>[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]</small>	First Draw (ppb) (See note 2) <small>[Enter non-detect/ numeric value]</small>	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/10/2019	
RESULTS DATE				8/12/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		9/17/2019	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	First Draw (ppb)			Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	2			0	0	0	0
Total Drinking > 15 ppb	0			0	0	0	0
Total Cook	6			0	0	0	0
Total Cook > 15 ppb	0			0	0	0	0
Total Washing	23			0	0	0	1
Total Washing > 15 ppb	1			0	0	0	0
Total Samples	31			0	0	0	1
Total Samples > 15 ppb	1			0	0	0	0

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River Youth Center
 Building No: 1597

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY <small>[Enter water's intended use]</small>	SAMPLE ID	Outlet Description <small>[Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]</small>	Comments <small>[Provide, for example, whether filter was removed, staining was present, any identifying marks]</small>	Lead Screening Level of 15ppb					Description <small>[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]</small>	Recommended Level = 15ppb		
				First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>	Retest required? <small>[Enter YES/NO]</small>	Date Fixture Secured? <small>[See Note 1]</small> <small>[Enter N/A if First Draw is ≤ 20ppb; otherwise enter mm/dd/yyyy]</small>	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>		Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	First Draw (ppb) <small>[See note 2]</small> <small>[Enter non-detect/ numeric value]</small>	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE				8/8/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
DRINKING	PX-1597-HLWZA-WFC-FD	WATER FOUNTAIN (COOLER), 2A--Hallway		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	PX-1597-HLW4B-WFC-FD	WATER FOUNTAIN (COOLER), 4B--Hallway		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
COOKING	PX-1597-K6A-K-FD	KITCHEN SINK FOR FOOD PREP, 6A--Kitchen		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-RM2A-HHWA-FD	HIGH HAND WASHING (girls) A, 2A--Bathroom Faucets		1.2	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-RM2A-HHWB-FD	HIGH HAND WASHING (girls) B, 2A--Bathroom Faucets		0.9	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-RM3A-HHWA-FD	HIGH HAND WASHING (boys) A, 3A--Bathroom Faucets		0.62	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-RM3A-HHWB-FD	HIGH HAND WASHING (boys) B, 3A--Bathroom Faucets		1.6	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-Bath3B-HHW-FD	HIGH HAND WASHING (adults), 3B--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-Bath4B-LHWA-FD	HIGH HAND WASHING FAUCET (girls) A, 4B--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-Bath4B-LHWB-FD	HIGH HAND WASHING FAUCET (girls) B, 4B--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-Bath5B-HHWA-FD	HIGH HAND WASHING (boys) A, 5B--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
WASHING	PX-1597-Bath5B-HHWB-FD	HIGH HAND WASHING (boys) B, 5B--Bathroom Faucets		non-detect	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Notes:
¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 20ppb.
² Post-remediation sampling was initially conducted on [ENTER DATE]. Additional [CORRECTIVE ACTIONS DESCRIPTION] were implemented and final results below recommended level of 20ppb for sample collected on [ENTER DATE] are shown on the table.

APPENDIX E - Sample Summary Results Table
 Priority Areas Lead Testing and Corrective Actions (01/2019)
 NAS Patuxent River Youth Center
 Building No: 1597

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY <small>[Enter water's intended use]</small>	SAMPLE ID	Outlet Description <small>[Enter, as a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]</small>	Comments <small>[Provide, for example, whether filter was removed, staining was present, any identifying marks]</small>	Lead Screening Level of 15ppb								
				First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>	Retest required? <small>[Enter YES/NO]</small>	Date Fixture Secured? <small>(See Note 1)</small> <small>[Enter N/A if First Draw is < 20ppb; otherwise enter mm/dd/yyyy]</small>	Water Fountain 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	First Draw (ppb) <small>[Enter non-detect/ numeric value]</small>	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>	Description <small>[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]</small>	First Draw (ppb) (See note 2) <small>[Enter non-detect/ numeric value]</small>	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) <small>[Enter non-detect/ numeric value]</small>
SAMPLING DATE				8/3/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	
RESULTS DATE				8/8/2019			mm/dd/yyyy	mm/dd/yyyy	mm/dd/yyyy		mm/dd/yyyy	

Table 2. Summary Statistics

CATEGORY	INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			POST REMEDIATION RESULTS
	Lead Screening Level of 15ppb						
	First Draw (ppb)			Water Fountain Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)	First Draw (ppb)
Total Drinking	2			0	0	0	0
Total Drinking > 15 ppb	0			0	0	0	0
Total Cook	1			0	0	0	1
Total Cook > 15 ppb	0			0	0	0	0
Total Washing	9			0	0	0	0
Total Washing > 15 ppb	0			0	0	0	0
Total Samples	12			0	0	0	1
Total Samples > 15 ppb	0			0	0	0	0