

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION- Building 2030				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST-CORRECTIVE ACTION SAMPLING RESULTS	
CATEGORY	SAMPLE ID (Use same nomenclature as baseline sample event)	Outlet Description (At a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable)	Comments (Provide, for example, whether filter was removed, staining was present, any identifying marks)	First Draw (ppb) [numeric value]	Retest required? [YES or NO]	Date Fixture Secured? (See Note 1) [N/A if First Draw is ≤ 15ppb; otherwise mm/dd/yyyy]	Water Fountain/Chiller 15 min. Follow up Flush Sample Collected day before First Draw Sampling (ppb) [numeric value]	First Draw (ppb) [numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [numeric value]	Description [Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement serator maintenance program]	First Draw (ppb) (See note 2) [numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [numeric value]
SAMPLING DATE RESULTS DATE				12/14/2024			N/A	N/A	N/A		N/A	
				1/24/2025			N/A	N/A	N/A		N/A	
Washing	664405-1	9A/10A - : HIGH HAND WASHING (adults), Infant room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-2	9A/10A - : LOW HAND WASHING FAUCET (youth), A, Infant room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-3	9A/10A - : LOW HAND WASHING FAUCET (youth), B, Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664405-4	11A - : KITCHEN SINK FOR FOOD PREP., Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-5	9 - : HIGH HAND WASHING (adults), Infant Room		0.90 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664405-6	9 - : KITCHEN SINK FOR FOOD PREP., Infant Room		0.73 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-7	8 - : HIGH HAND WASHING (adults), Pretoddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664405-8	8 - : KITCHEN SINK FOR FOOD PREP., Pretoddler Room		0.62 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-9	8 - : KITCHEN SPRAYER, Pretoddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-10	7 - : LOW HAND WASHING FAUCET (youth), A, Infant Room		1.3 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-11	7 - : LOW HAND WASHING FAUCET (youth), B, Infant Room		0.86 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-12	7 - : LOW HAND WASHING FAUCET (youth), C, Infant Room		0.93 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-13	6 - : LOW HAND WASHING FAUCET (youth), A, Infant Room		1.3 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-14	6 - : LOW HAND WASHING FAUCET (youth), B, Infant Room		0.84 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-15	6 - : LOW HAND WASHING FAUCET (youth), C, Infant Room		0.66 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-16	5 - : LOW HAND WASHING FAUCET (youth), A, Infant Room		0.83 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-17	5 - : LOW HAND WASHING FAUCET (youth), B, Infant Room		0.75 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-18	5 - : LOW HAND WASHING FAUCET (youth), C, Infant Room		0.95 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-19	2 - : HIGH HAND WASHING (adults), Bathroom Faucets		1.3 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664405-20	HLW - : WATER FOUNTAIN (BUBBLER), Hallway		3.4 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-21	3 - : HIGH HAND WASHING (adults), Bathroom Faucets		2.6 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-22	HLW - : HIGH HAND WASHING (adults), Hallway		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-23	11A - : KITCHEN SPRAYER, Kitchen		1.6 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664405-24	11B - : KITCHEN FOOD PREP SINK, Kitchen		1.7 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-25	4 - : LOW HAND WASHING FAUCET (youth), A, Training Room		1.1 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-26	4 - : LOW HAND WASHING FAUCET (youth), B, Infant Room		5.1 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-27	4 - : LOW HAND WASHING FAUCET (youth), C, Infant Room		0.74 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-28	4A/5A - : LOW HAND WASHING FAUCET (youth), A, Pretoddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-29	4A/5A - : LOW HAND WASHING FAUCET (youth), B, Pretoddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664405-30	4A/5A - : LOW HAND WASHING FAUCET (youth), C, Pretoddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION- Building 2813				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST-CORRECTIVE ACTION SAMPLING	
CATEGORY	SAMPLE ID [Use same nomenclature as baseline sample event]	Outlet Description [At a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]	Comments [Provide, for example, whether filter was removed, staining was present, any identifying marks]	Lead Screening Level of 10 ppb			Lead Screening Level of 10 ppb			Description [Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]	Recommended Level = 10 ppb	
				First Draw (ppb) [numeric value]	Retest required? [YES or NO]	Date Fixture Secured? (See Note 1) [N/A if First Draw is ≤ 15ppb; otherwise mm/dd/yyyy]	Water Fountain/Chiller 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb) [numeric value]	First Draw (ppb) [numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [numeric value]		First Draw (ppb) (See note 2) [numeric value]	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb) [numeric value]
SAMPLING DATE RESULTS DATE				12/20/2024			N/A	N/A	N/A		N/A	
				1/24/2025			N/A	N/A	N/A		N/A	
Washing	664407-1	101 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-2	101 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-3	101 - : LOW HAND WASHING FAUCET (youth) , Infant Room		1.3 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-4	101 - : KITCHEN SPRAYER , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-5	102 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-6	102 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-7	102 - : LOW HAND WASHING FAUCET (youth) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-8	102 - : KITCHEN SPRAYER , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-9	103 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-10	103 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-11	103 - : LOW HAND WASHING FAUCET (youth) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-12	103 - : KITCHEN SPRAYER , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-13	104 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-14	104 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-15	104 - : LOW HAND WASHING FAUCET (youth), A, Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-16	105 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-17	105 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-18	105 - : KITCHEN SPRAYER , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-19	105 - : LOW HAND WASHING FAUCET (youth) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664407-20	105 - : WATER FOUNTAIN (BUBBLER) , OUTSIDE		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-21	106 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-22	106 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-23	106 - : KITCHEN SPRAYER , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-24	110 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-25	110 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-26	110 - : KITCHEN SPRAYER , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-27	110 - : LOW HAND WASHING FAUCET (youth) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-28	111 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-29	111 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-30	111 - : KITCHEN SPRAYER , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-31	111 - : LOW HAND WASHING FAUCET (youth) , Infant Room		0.53 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-32	112 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-33	112 - : KITCHEN SINK FOR FOOD PREP , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-34	112 - : KITCHEN SPRAYER , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-35	112 - : LOW HAND WASHING FAUCET (youth) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-36	113 - : HIGH HAND WASHING (adults) , Infant Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

[illegible]

	Washing	664407-89	140 - : LOW HAND WASHING FAUCET (youth), B, Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-90	140 - : LOW HAND WASHING FAUCET (youth), C, Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Drinking	664407-91	140 - : WATER FOUNTAIN (BUBBLER) , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-92	141 - : HIGH HAND WASHING (adults) , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Cooking	664407-93	141 - : KITCHEN SINK FOR FOOD PREP , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-94	141 - : KITCHEN SPRAYER , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-95	141 - : LOW HAND WASHING FAUCET (youth), A, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-96	141 - : LOW HAND WASHING FAUCET (youth), B, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-97	141 - : LOW HAND WASHING FAUCET (youth), C, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-98	142 - : HIGH HAND WASHING (adults) , Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Cooking	664407-99	142 - : KITCHEN SINK FOR FOOD PREP , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-100	142 - : KITCHEN SPRAYER , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-101	142 - : LOW HAND WASHING FAUCET (youth), A, Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-102	142 - : LOW HAND WASHING FAUCET (youth), B, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-103	142 - : LOW HAND WASHING FAUCET (youth), C, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Drinking	664407-104	142 - : WATER FOUNTAIN (BUBBLER) , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-105	143 - : HIGH HAND WASHING (adults) , Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Cooking	664407-106	143 - : KITCHEN SINK FOR FOOD PREP , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-107	143 - : KITCHEN SPRAYER , Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-108	143 - : LOW HAND WASHING FAUCET (youth), A, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-109	143 - : LOW HAND WASHING FAUCET (youth), B, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-110	143 - : LOW HAND WASHING FAUCET (youth), C, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Drinking	664407-111	143 - : WATER FOUNTAIN (BUBBLER) , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-112	144 - : HIGH HAND WASHING (adults) , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Cooking	664407-113	144 - : KITCHEN SINK FOR FOOD PREP , Preschool Room,	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-114	144 - : KITCHEN SPRAYER , Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-115	144 - : LOW HAND WASHING FAUCET (youth), A, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-116	144 - : LOW HAND WASHING FAUCET (youth), B, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-117	144 - : LOW HAND WASHING FAUCET (youth), C, Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Drinking	664407-118	144 - : WATER FOUNTAIN (BUBBLER) , , Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-119	145 - : HIGH HAND WASHING (adults) , , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Cooking	664407-120	145 - : KITCHEN SINK FOR FOOD PREP , , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-121	145 - : KITCHEN SPRAYER , , Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-122	145 - : LOW HAND WASHING FAUCET (youth), A , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-123	145 - : LOW HAND WASHING FAUCET (youth), B , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-124	145 - : LOW HAND WASHING FAUCET (youth), C , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Drinking	664407-125	145 - : WATER FOUNTAIN (BUBBLER) , , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-126	146 - : HIGH HAND WASHING (adults) , , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Cooking	664407-127	146 - : KITCHEN SINK FOR FOOD PREP , , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-128	146 - : KITCHEN SPRAYER , , Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-129	146 - : LOW HAND WASHING FAUCET (youth), A , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-130	146 - : LOW HAND WASHING FAUCET (youth), B , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-131	146 - : LOW HAND WASHING FAUCET (youth), C , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Drinking	664407-132	146 - : WATER FOUNTAIN (BUBBLER) , , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-133	147 - : HIGH HAND WASHING (adults) , , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Cooking	664407-134	147 - : KITCHEN SINK FOR FOOD PREP , , Toddler Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
	Washing	664407-135	147 - : KITCHEN SPRAYER , , Preschool Room	< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Washing	664407-136	147 - : LOW HAND WASHING FAUCET (youth), A , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-137	147 - : LOW HAND WASHING FAUCET (youth), B , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-138	148 - : HIGH HAND WASHING (adults), , , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-139	148 - : KITCHEN SINK FOR FOOD PREP, , , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-140	148 - : KITCHEN SPRAYER, , , Preschool Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-141	148 - : LOW HAND WASHING FAUCET (youth), A , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-142	148 - : LOW HAND WASHING FAUCET (youth), B , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-143	148 - : LOW HAND WASHING FAUCET (youth), C , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664407-144	148 - : WATER FOUNTAIN (BUBBLER), , , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-145	149 - : HIGH HAND WASHING (adults), , , Toddler Room		0.85 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-146	149 - : KITCHEN SINK FOR FOOD PREP, , , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-147	149 - : KITCHEN SPRAYER, , , Preschool Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-148	149 - : LOW HAND WASHING FAUCET (youth), A , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-149	149 - : LOW HAND WASHING FAUCET (youth), B , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-150	149 - : LOW HAND WASHING FAUCET (youth), C , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664407-151	149 - : WATER FOUNTAIN (BUBBLER), , , Toddler Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-152	130 - : HIGH HAND WASHING (adults), A , Bathroom Faucets		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-153	132 - : HIGH HAND WASHING (adults), B , Bathroom Faucets		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-154	119 - : HIGH HAND WASHING (adults)-CDC DIR, A , Bathroom Faucets		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-155	120 - : HIGH HAND WASHING (adults)-CDC DIR, B , Bathroom Faucets		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664407-156	WATER FOUNTAIN HIGH, , , Hallway		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664407-157	WATER FOUNTAIN LOW, , , Hallway		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664407-158	137 - : KITCHEN PASTA BOILER, , , Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-159	140 - : LOW HAND WASHING FAUCET (youth), A , Preschool Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664407-160	140 - : KITCHEN SPRAYER, , , Preschool Room		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664407-321	116 - : WATER FOUNTAIN (BUBBLER), , Infant Room,		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION- Building 2815				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST-CORRECTIVE ACTION SAMPLING	
CATEGORY	SAMPLE ID	Outlet Description	Comments	First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain/Chiller 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		Description	First Draw (ppb) (See note 2)
[Water's intended use]	[Use same nomenclature as baseline sample event]	[At a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]	[Provide, for example, whether filter was removed, staining was present, any identifying marks]	[numeric value]	[YES or NO]	[N/A if First Draw is ≤ 15ppb; otherwise mm/dd/yyyy]	[numeric value]	[numeric value]	[numeric value]	[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]	[numeric value]	[numeric value]
SAMPLING DATE				12/14/2024			N/A	N/A	N/A		N/A	
RESULTS DATE				1/24/2025			N/A	N/A	N/A		N/A	
Washing	664408-2	BATHROOM FAUCETS, A, Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-3	BATHROOM FAUCETS, B, Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-4	BATHROOM FAUCETS, C, Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-5	AUTOMATIC BATHROOM FAUCETS, A, Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-6	AUTOMATIC BATHROOM FAUCETS, C, Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-7	AUTOMATIC BATHROOM FAUCETS, D, Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664408-8	WATER FOUNTAIN HIGH, , Hallway,		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664408-9	WATER FOUNTAIN LOW, , Hallway		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-10	LOW HAND WASHING FAUCET, , Banquet Bar		0.60 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-11	HIGH HAND WASH (Adult), A, Conference Center		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-12	HIGH HAND WASH (Adult), B, Conference Center		1.4 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-13	HIGH HAND WASH (Adult), C, Conference Center, ICP		2.0 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-14	BATHROOM FAUCETS, , Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-15	BATHROOM FAUCETS, , Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-16	HIGH HAND WASH (Adult), , Ladies Office		0.76 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664408-17	KITCHEN SINK FOR FOOD PREP, , Kitchen		2.7 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-18	HIGH HAND WASH (Adult), A, Kitchen		1.4 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-19	KITCHEN SPRAYER, , Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-20	HIGH HAND WASH (Adult), B, Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-21	HIGH HAND WASH (Adult), C, Kitchen		1.2 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-22	KITCHEN SPRAYER, , Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664408-23	KITCHEN SINK FOR FOOD PREP, A, Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664408-24	KITCHEN SINK FOR FOOD PREP, B, Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-25	HIGH HAND WASH (Adult), C, Kitchen		2.3 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664408-26	KITCHEN SINK FOR FOOD PREP, A, Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664408-27	KITCHEN SINK FOR FOOD PREP, B, Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-28	HIGH HAND WASH (Adult), , Kitchen		0.82 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Cooking	664408-29	KITCHEN PASTA BOILER, , Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664408-30	HIGH HAND WASH (Adult), Single, Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Drinking	664408-31	ICE MACHINE, , Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST-CORRECTIVE ACTION SAMPLING	
CATEGORY  [Water's intended use]	SAMPLE ID  [Use same nomenclature as baseline sample event]	Outlet Description  [At a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]	Comments  [Provide, for example, whether filter was removed, staining was present, any identifying marks]	Lead Screening Level of 10 ppb			Lead Screening Level of 10 ppb			Description  [Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]	Recommended Level = 10 ppb	
				First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain/Chiller 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
				[numeric value]	[YES or NO]	[N/A if First Draw is ≤ 15ppb; otherwise mm/dd/yyyy]	[numeric value]	[numeric value]	[numeric value]		[numeric value]	
SAMPLING DATE				2/6/2025			N/A	N/A	N/A		N/A	
RESULTS DATE				2/20/2025			N/A	N/A	N/A		N/A	
Washing	665909-1	HIGH HAND WASH (Adult), Office		1.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	665909-2	HIGH HAND WASH (Adult), Office		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	665909-3	HIGH HAND WASH (Adult), Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	665909-4	HIGH HAND WASH (Adult), Kitchen		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION- Building 2956				INITIAL SAMPLING RESULTS			RE-SAMPLING RESULTS			CORRECTIVE ACTIONS	POST-CORRECTIVE ACTION SAMPLING	
CATEGORY	SAMPLE ID	Outlet Description	Comments	Lead Screening Level of 10 ppb			Lead Screening Level of 10 ppb			Description	Recommended Level = 10 ppb	
				First Draw (ppb)	Retest required?	Date Fixture Secured? (See Note 1)	Water Fountain/Chiller 15 min. Follow up Flush Sample - Collected day before First Draw Sampling (ppb)	First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)		First Draw (ppb) (See note 2)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
[Water's intended use]	[Use same nomenclature as baseline sample event]	[At a minimum, room number and type of outlet; include filter identification and whether a motion sensor faucet or blended water, as applicable]	[Provide, for example, whether filter was removed, staining was present, any identifying marks]	[numeric value]	[YES or NO]	[N/A if First Draw is ≤ 15ppb; otherwise mm/dd/yyyy]	[numeric value]	[numeric value]	[numeric value]	[Enter brief description of remediation activities; for example, replace fixture, add a point of use device, check grounding wires, replace lead piping, reconfigure piping, permanently close outlet, implement aerator maintenance program]	[numeric value]	[numeric value]
SAMPLING DATE				12/14/2024			N/A	N/A	N/A		N/A	
RESULTS DATE				1/7/2025			N/A	N/A	N/A		N/A	
DRINKING	664403-1	WATER FOUNTAIN, , Hallway		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
DRINKING	664403-2	BOTTLE FILLER, , Hallway		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664403-3	BATHROOM FAUCETS, , Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A
Washing	664403-4	BATHROOM FAUCETS, , Bathroom		< 0.5 ppb	NO	N/A	N/A	N/A	N/A	Routine Control Measures Only	N/A	N/A