

## WEEKLY UPDATE FOR HOT WATER REPAIRS IN BLDGS. 60 AND 64

### BLDG 60:

- **Update 6: 16MAR22:** Sampling results confirm the water in Bldg. 60 is safe and reliable. The hot water project in this building is now complete.
- **Update 5: 09MAR22:** Sanitization of the domestic water system in Bldg. 60 was completed last week. The installation is awaiting sampling results to confirm the water is safe and reliable.
- **Update 4: 02MAR22:** Sanitization of the domestic water system in Bldg. 60 is scheduled for completion this week. Samples will be taken at each faucet and shower head, confirming the water is safe and reliable. NSAB staff will conduct a final test to confirm the new system is able to distribute sufficient hot water to residents' rooms during high demand.
- **Update 3: 24FEB22:** With Bldg. 60's new hot water circulation loop in place and new supporting components installed, the building's domestic hot water system will now go through Testing, Adjusting, and Balancing (TAB) and then be sanitized in accordance with Unified Facilities Criteria. These steps will confirm the system is operating properly.
- **Update 2: 18FEB22:** The new hot water recirculation line we began installing in mid-December has been installed and pressure tested, along with new control valves in the hot water distribution system. Shower diverters (the component in each shower that mixes hot and cold water) have been replaced in every room, as well as the sink faucets. The building will be put through a rigorous commissioning process, to include quality of life repairs, prior to being reopened to residents. Additional HVAC system investigation and repairs are ongoing. The expected reopening date of Bldg. 60 remains unknown.
- **Update 1: 09FEB22:** Water is secured in Bldg. 60. The contractor has started connecting the newly constructed hot water loop to the main system. Numerous system mixing valves are also being replaced.

### BLDG 64:

- **Update 6: 16MAR22:** Hot water repairs in Bldg. 64 are complete, however, the system is being monitored to ensure consistent performance as relocated UH residents begin to move in from alternate lodging.
- **Update 5: 09MAR22:** Work to ensure hot water production capacity is complete in Bldg. 64. Testing and adjusting of the hot water distribution system will continue throughout this week.
- **Update 4: 02MAR22:** Improvements to Bldg. 64's hot water distribution system are on track. Testing, adjusting, and balancing (TAB) will be performed by the end of the week.
- **Update 3: 24FEB22:** Bldg. 64's domestic hot water system is scheduled for additional repairs next week. Hot water will be offline from 7 a.m. to 5 p.m. on Monday and Tuesday (Feb. 28 & March 1) followed by Testing, Adjusting, and Balancing (TAB) by the end of the week.
- **Update 2: 15FEB22:**
  - **Hot Water Update:** Plans to replace additional water valves throughout the building are moving forward.
  - **Heating Update:** Air temperature verifications have been completed; any further issues will need to be addressed through individual trouble calls. If you're experiencing a heating issue, please report it via the maintenance log as soon as possible.
- **Update 1: 09FEB22:** Our public works department identified an issue with a mixing valve that has been repaired. Another significant issue involving one of the hot water heaters was also identified and repaired. Public Works will continue to evaluate system performance to identify any other issues that could impact the supply of hot water.