

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
NAPS, BLDG NA74 1st LEVEL HALLWAY	WATER FOUNTAIN (COOLER)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 1st LEVEL HALLWAY	WATER FOUNTAIN (COOLER)- BOTTLE FILLER	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 2nd LEVEL HALLWAY	WATER FOUNTAIN (COOLER)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 2nd LEVEL HALLWAY	WATER FOUNTAIN (COOLER)- BOTTLE FILLER	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 BATH	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 BATH	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 KITCHEN	KITCHEN SPRAYER	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 KITCHEN	KITCHEN SINK	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 109	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 109	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
NAPS, BLDG NA74 ROOM 109	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 109	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 201	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 201	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 202	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 203	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 204	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 205	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 206	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
NAPS, BLDG NA74 ROOM 207	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
Legend: N/A - Not Applicable ppb - parts per billion							

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
CDC, BLDG 297NS HALLWAY	WATER FOUNTAIN (COOLER)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A101	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A101	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A101	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A102	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A102	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A102	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A103	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A103	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A103	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A104	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A104	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
CDC, BLDG 297NS ROOM A104	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A105	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A105	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A105	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A106	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A106	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A106	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A107	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A107	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A107	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A108	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A108	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A108	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
CDC, BLDG 297NS ROOM A110	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A110	KITCHEN SINK FOR FOOD PREP	3.4 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A110	KITCHEN SINK FOR FOOD PREP	0.61 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM A110	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B134	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B134	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B134	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B134	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B134	WATER FOUNTAIN (BUBBLER)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B135	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B135	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B135	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B135	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
CDC, BLDG 297NS ROOM B135	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B135	WATER FOUNTAIN (BUBBLER)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B136	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B136	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B136	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B136	LOW HAND WASHING FAUCET (youth)	0.62 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B136	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B136	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B136	WATER FOUNTAIN (BUBBLER)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B137	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B137	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B137	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B137	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
CDC, BLDG 297NS ROOM B137	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B137	WATER FOUNTAIN (BUBBLER)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B139	HIGH HAND WASHING (adults)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B139	KITCHEN SINK FOR FOOD PREP	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B139	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B139	LOW HAND WASHING FAUCET (youth)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM B139	WATER FOUNTAIN (BUBBLER)	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM CA011	HIGH HAND WASHING (adults)-BATHROOM	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM CA012	HIGH HAND WASHING (adults)-BATHROOM	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM CA012	HIGH HAND WASHING (adults)-BATHROOM	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
CDC, BLDG 297NS ROOM N19	KITCHEN SINK FOR FOOD PREP-TEACHER'S LOUNGE	< 0.5 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
Legend: N/A - Not Applicable ppb - parts per billion							

		Lead Testing Threshold of 15 ppb														CORRECTIVE ACTIONS	
		INITIAL SAMPLING RESULTS					1st RE-SAMPLING RESULTS					2nd RE-SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Re-Sample first Draw Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Re-Sample first Draw Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
CDC, BLDG 298NS ROOM 100	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 102	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 102	KITCHEN SINK FOR FOOD PREP	5.2 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 103	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 103	LOW HAND WASHING FAUCET (youth)	16.1 ppb	10.8 ppb	1/26/2019	2/4/2019	YES	130 ppb	0.57 ppb	3/13/2019	3/18/2019	YES	<1 ppb	<1 ppb	4/3/2019	4/8/2019	NO	Replaced faucet (3/04); Replaced aerator (3/28)
CDC, BLDG 298NS ROOM 103	LOW HAND WASHING FAUCET (youth)	3.8 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 103	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 103	WATER FOUNTAIN (BUBBLER)	1.3 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 104	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 104	LOW HAND WASHING FAUCET (youth)	33.4 ppb	11.6 ppb	1/26/2019	2/4/2019	YES	32 ppb	<0.5 ppb	3/13/2019	3/18/2019	YES	<1 ppb	<1 ppb	4/3/2019	4/8/2019	NO	Replaced faucet (3/04); Replaced aerator (3/28)
CDC, BLDG 298NS ROOM 104	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 104	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 104	WATER FOUNTAIN (BUBBLER)	4.1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 107	HIGH HAND WASHING FACUET BATHROOM	<1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 108	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 108	KITCHEN SINK FOR FOOD PREP	1.4 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 108	KITCHEN SPRAYER	4.6 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 108	UTILITY SINK	2.2 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 108	WATER FOUNTAIN (COOLER)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 109	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 109	KITCHEN SINK FOR FOOD PREP	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 110	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 110	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 110	LOW HAND WASHING FAUCET (youth)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 110	LOW HAND WASHING FAUCET (youth)	3.1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 110	WATER FOUNTAIN (BUBBLER)	<1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 120	HIGH HAND WASHING (adults)	<1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 120	LOW HAND WASHING FAUCET (youth)	<1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
CDC, BLDG 298NS ROOM 120	LOW HAND WASHING FAUCET (youth)	<1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A



		Lead Testing Threshold of 15 ppb														CORRECTIVE ACTIONS	
Sample Location	Outlet Description	INITIAL SAMPLING RESULTS					1st RE-SAMPLING RESULTS					2nd RE-SAMPLING RESULTS					
		Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Re-Sample first Draw Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Re-Sample first Draw Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
CDC, BLDG 298NS ROOM 120	WATER FOUNTAIN (BUBBLER)	<1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Legend: N/A - Not Applicable ppb - parts per billion																	

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
YOUTH CENTER, BLDG 345NS HALLWAY	WATER FOUNTAIN (COOLER)-BOTTLE FILLER	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS HALLWAY	WATER FOUNTAIN (COOLER)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 107	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 115	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 115	WATER FOUNTAIN (BUBBLER)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 116	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 116	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 116	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
YOUTH CENTER BLDG 345NS ROOM 117	HIGH HAND WASHING (adults)	2 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 117	Utility Sink	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 117	WATER FOUNTAIN (BUBBLER)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 118	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 118	WATER FOUNTAIN (BUBBLER)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 119	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 119	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 119	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 120	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A

		Lead Testing Threshold of 15 ppb					CORRECTIVE ACTIONS
		INITIAL SAMPLING RESULTS					
Sample Location	Outlet Description	Initial First Draw Sampling Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Retest required?	Description
YOUTH CENTER, BLDG 345NS ROOM 120	WATER FOUNTAIN (BUBBLER)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 121	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 121	KITCHEN SPRAYER	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 122	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
YOUTH CENTER, BLDG 345NS ROOM 123	HIGH HAND WASHING (adults)	< 1 ppb	N/A	1/26/2019	2/4/2019	NO	N/A
Legend: N/A - Not Applicable ppb - parts per billion							