

LEAD IN PRIORITY AREAS SAMPLE RESULTS 2014
NAVAL SUPPORT ACTIVITY, ANNAPOLIS

SAMPLING LOCATION DESCRIPTION			Lead Screening Level of 20ppb								CORRECTIVE ACTIONS	
			INITIAL SAMPLING RESULTS				RE-SAMPLING RESULTS					
CATEGORY	SAMPLE ID	Outlet Description	Initial First Draw Sampling Result (ppb)	Sampling Date	Results Date	Retest required?	Date Fixture Secured?	Re-Sample first Draw Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Description
DRINKING	AN-126NS-Bath28-HHWA	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-126NS-Bath28-HHWP	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-126NS-Bath28-HHWC	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-126NS-Bath28-HHWD	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-126NS-K28-K	Kitchen Sink for Food Prep	3.1	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-126NS-OUT102-WS	Water Spigot	20	10/25/2014	10/27/2014	YES	10/24/2014	13	N/A	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-126NS-RM102-WFC	Water Fountain (Cooler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-126NS-TLHW8-HHWA	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-126NS-UTHW8-HHWP	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-BathCA011-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-BathCA012-HHWA	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-BathCA012-HHWP	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-HLWCA012-WFC	Water Fountain (Cooler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-INFA102-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-INFA104-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-INFA106-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-INFA108-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-KA110-HHW	High Hand Washing (adults)	16	10/25/2014	10/27/2014	NO	10/24/2014	7.1	N/A	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-297NS-KA110-KA	Kitchen Sink for Food Prep	1.6	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-KA110-KB	Kitchen Sink for Food Prep	4.3	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-KA110-KC	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-KA110-KD	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-OUTA101-WS	Water Spigot	5.2	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-OUTA104-WS	Water Spigot	27	10/25/2014	10/27/2014	YES	10/27/2014	310	3.3	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-297NS-OUTB134-WS	Water Spigot	7.6	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-OUTB136-WFB	Water Fountain (Bubbler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-OUTB137-WFB	Water Fountain (Bubbler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-OUTB139-WS	Water Spigot	4.2	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHA101-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHA103-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHA105-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHA107-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHB134-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHB134-LHWA	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHB134-WFB	Water Fountain (Bubbler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHB136-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHB136-LHWA	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-PSHB136-WFB	Water Fountain (Bubbler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-TLN19-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-TLN19-WFC	Water Fountain (Cooler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-TODDB135-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A

SAMPLING LOCATION DESCRIPTION			Lead Screening Level of 20ppb									CORRECTIVE ACTIONS
			INITIAL SAMPLING RESULTS					RE-SAMPLING RESULTS				
CATEGORY	SAMPLE ID	Outlet Description	Initial First Draw Sampling Result (ppb)	Sampling Date	Results Date	Retest required?	Date Fixture Secured?	Re-Sample first Draw Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Description
DRINKING	AN-297NS-TODDB137-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-TODDB139-K	Kitchen Sink for Food Prep	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-TODDB139-LHWA	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-TODDB139-WFB	Water Fountain (Bubbler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-297NS-UTLAUNDRY-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-HLW108-WCF	Water Fountain (Cooler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF102-HHW	High Hand Washing (adults)	7.2	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF102-K	Kitchen Sink for Food Prep	4.6	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF103-HHW	High Hand Washing (adults)	3.4	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF103-LHWC	Low Hand Washing Faucet (youth)	6.3	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF103-WFB	Water Fountain (Bubbler)	9.4	10/25/2014	10/27/2014	NO	10/24/2014	4.8	N/A	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-298NS-INF104-HHW	High Hand Washing (adults)	1.7	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF104-LHWC	Low Hand Washing Faucet (youth)	3.2	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF104-WFB	Water Fountain (Bubbler)	2.3	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF109-HHW	High Hand Washing (adults)	3.5	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-INF109-K	Kitchen Sink for Food Prep	2.8	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-K108-HHWA	High Hand Washing (adults)	32	10/25/2014	10/27/2014	YES	10/24/2014	15	N/A	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-298NS-K108-HHWA	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-K108-KA	Kitchen Sink for Food Prep	5.1	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-K108-KB	Kitchen Sink for Food Prep	11	10/25/2014	10/27/2014	NO	10/24/2014	13	N/A	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-298NS-K108-KSP	Kitchen Sprayer	9.5	10/25/2014	10/27/2014	NO	10/24/2014	6.5	N/A	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-298NS-OUT102-WS	Water Spigot	5.9	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-OUT103-WS	Water Spigot	6.7	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-OUT104-WFB	Water Fountain (Bubbler)	1.1	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-OUT108-WS	Water Spigot	11	10/25/2014	10/27/2014	NO	10/24/2014	26	11	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-298NS-OUT110-WFB	Water Fountain (Bubbler)	2	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-OUT110-WS	Water Spigot	13	10/25/2014	10/27/2014	NO	10/24/2014	74	19	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-298NS-OUT120-WFB	Water Fountain (Bubbler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-OUT120-WSA	Water Spigot	11	10/25/2014	10/27/2014	NO	10/24/2014	29	3.6	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-298NS-OUT120-WSB	Water Spigot	20	10/25/2014	10/27/2014	YES	10/24/2014	10	N/A	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-298NS-PSH110-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-PSH110-LHWC	Low Hand Washing Faucet (youth)	3.6	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-PSH110-WFB	Water Fountain (Bubbler)	2.9	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-PSH120-HHW	High Hand Washing (adults)	2	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-PSH120-LHWC	Low Hand Washing Faucet (youth)	3.1	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-PSH120-WFB	Water Fountain (Bubbler)	1.6	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-TL100-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-298NS-UT108-KUT	Utility Sink	1.9	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-HLW116-WFCA	Water Fountain (Cooler)	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A

SAMPLING LOCATION DESCRIPTION			Lead Screening Level of 20ppb									CORRECTIVE ACTIONS
			INITIAL SAMPLING RESULTS				RE-SAMPLING RESULTS					
CATEGORY	SAMPLE ID	Outlet Description	Initial First Draw Sampling Result (ppb)	Sampling Date	Results Date	Retest required?	Date Fixture Secured?	Re-Sample first Draw Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Description
DRINKING	AN-345NS-HLW116-WFCB	Water Fountain (Cooler)	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-K121-HHW	High Hand Washing (adults)	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-K121-KSP	Kitchen Sprayer	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-OUT105-WS	Water Spigot	5.9	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-OUT115-WS	Water Spigot	15	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-OUT117-WFB	Water Fountain (Bubbler)	1.5	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-OUT118-WS	Water Spigot	11	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-OUT124-WS	Water Spigot	6.9	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-RM115-HHW	High Hand Washing (adults)	2.6	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-RM115-WFB	Water Fountain (Bubbler)	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-RM117-HHW	High Hand Washing (adults)	3.6	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-RM117-WFB	Water Fountain (Bubbler)	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-RM118-HHW	High Hand Washing (adults)	2.8	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-RM118-WFB	Water Fountain (Bubbler)	1.3	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-RM120-HHW	High Hand Washing (adults)	2.6	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-RM120-WFB	Water Fountain (Bubbler)	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-STR117-UT	Utility Sink	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-TL107-HHW	High Hand Washing (adults)	1.7	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-345NS-UT114-HHW	High Hand Washing (adults)	ND	11/4/2014	11/10/2014	NO	11/3/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-Bath109-LHWA	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-Bath109-LHWB	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-Bath109-LHWC	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-Bath109-LHWD	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-BATHL-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-BathL-LHWA	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-BathL-LHWB	Low Hand Washing Faucet (youth)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-HLW205 H-WCF	Water Fountain (Cooler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-HLWL-WCF	Water Fountain (Cooler)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-KL-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-KL-KSP	Kitchen Sprayer	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-OUTF-WS	Water Spigot	3.4	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-OUTL-WS	Water Spigot	22	10/25/2014	10/27/2014	YES	10/24/2014	44	5.5	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-NA74-OUTR-WS	Water Spigot	6.0	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RM201-HHWA	High Hand Washing (adults)	1.2	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RM201-HHWB	High Hand Washing (adults)	1.1	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RM202-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RM203-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RM204-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RM205-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RM206-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RM207-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RMR-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-RMR-KSP	Kitchen Sprayer	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A
DRINKING	AN-NA74-STRS-HHW	High Hand Washing (adults)	9.7	10/25/2014	10/27/2014	NO	10/24/2014	3.1	N/A	11/25/2014	11/26/2014	REPLACED FIXTURE AFTER INITIAL SAMPLING
DRINKING	AN-NA74-UTJanitor-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A

SAMPLING LOCATION DESCRIPTION			Lead Screening Level of 20ppb								CORRECTIVE ACTIONS	
			INITIAL SAMPLING RESULTS				RE-SAMPLING RESULTS					
CATEGORY	SAMPLE ID	Outlet Description	Initial First Draw Sampling Result (ppb)	Sampling Date	Results Date	Retest required?	Date Fixture Secured?	Re-Sample first Draw Result (ppb)	Follow up Flush [Collected 30 seconds after First Draw Sampling (ppb)]	Sampling Date	Results Date	Description
DRINKING	AN-NA74-UTLAUNDRY-HHW	High Hand Washing (adults)	ND	10/25/2014	10/27/2014	NO	10/24/2014	ND	N/A	N/A	N/A	N/A