



DEPARTMENT OF THE NAVY
NAVAL SUPPORT ACTIVITY BETHESDA
4655 TAYLOR ROAD
BETHESDA MARYLAND 20889-5639

5090
Ser N4/0062
March 26, 2020

Dear Parent or Caregiver:

SUBJECT: LEAD IN PRIORITY AREA SAMPLING RESULTS

The Navy is committed to maintaining safe drinking water on its installations. Because lead exposure is a particular concern for children, and lead may be added to drinking water through the pipes, fittings, solder, and fixtures inside a building, the Environmental Protection Agency (EPA) recommends, but does not mandate, that we test the lead content of drinking water in priority areas such as schools and childcare facilities. The Navy has adopted the recommendation as policy.

At the Naval Support Activity Bethesda Child Development Centers (CDCs) and Austin's Playroom, outlets used for drinking, cooking, and washing were tested. Out of 231 total samples collected at the CDCs and Austin's Playroom, 2 water outlets in CDC Bldg. 26 initially tested above the EPA-recommended screening level of 15 parts per billion (ppb). After receiving the results, both outlets were immediately taken out of service.

One of the outlets was replaced and a sample was retaken to check the lead concentration in the water. The outlet now has a lead concentration below the 15 ppb standard. The other outlet is to be removed and will not be placed back in service. All outlets are now below the 15 ppb standard. Enclosed for your information are the full summary of results and corrective actions.

To learn more about lead in drinking water in schools and day care centers, visit the following EPA website: <https://www.epa.gov/dwreinfo/lead-drinking-water-schools-and-child-care-facilities>.

To answer any questions you may have on these sampling results, please contact the Environmental Program Director, Ms. Susan Paul, at (301) 295-2482.

Sincerely,

A handwritten signature in black ink, appearing to read "M. S. SEYMOUR", is written over a horizontal line.

M. S. SEYMOUR
Captain, Medical Service Corps
U. S. Navy
Commanding Officer

Enclosure: Full Summary of Results

Copy to:
CNIC Washington DC (N45)
NAVFACENGCOM Headquarters (EV)
NAVFACENGCOM Washington DC (EV1)

Table 1. Summary of Results

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS (Threshold of 15 ppb)			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Follow up Flush [(collected 30 seconds after First Draw (ppb))]	Description	Recommended Level = 15ppb	
							First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/6/2019				6/25/2019	
RESULTS DATE			4/16/2019				7/1/2019	
DRINKING	WR-26-OUT120-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), OUTSIDE120	15.7	YES	5.2	Device removed from use	N/A	N/A
DRINKING	WR-26-OUT132-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), OUTSIDE132	1.2	NO		Device not working properly, replaced	N/A	N/A
COOKING	WR-26-TL107-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Staff Lounge107	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-TL107-KSP-FD 1st Draw	KITCHEN SPRAYER, Staff Lounge107	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF111-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room111	32.8	YES	non-detect	Replace fixture	2.5	non-detect
COOKING	WR-26-INF111-KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room111	1.5	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF111-KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room111	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF112-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room112	1	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF112-KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room112	0.55	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF113-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room113	0.99	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF113-KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room113	0.93	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF113-KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room113	0.71	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF114-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room114	1.5	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF114-KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room114	0.78	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF114-KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room114	0.68	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF115-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room115	0.85	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF115-HHS:KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room115	0.61	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF115-KSP-FD 1st Draw	KITCHEN SPRAYER, Infant Room115	0.6	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH117-KSP-FD 1st Draw	KITCHEN SPRAYER, Pre-Toddler117	0.79	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH118-KSP-FD 1st Draw	KITCHEN SPRAYER, Pre-Toddler118	0.56	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH119-KSP-FD 1st Draw	KITCHEN SPRAYER, Pre-Toddler119	1.2	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH120-KSP-FD 1st Draw	KITCHEN SPRAYER, Pre-Toddler120	1.3	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH121-KSP-FD 1st Draw	KITCHEN SPRAYER, Pre-Toddler121	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH122-KSP-FD 1st Draw	KITCHEN SPRAYER, Pre-Toddler122	1.2	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH131-KSP-FD 1st Draw	KITCHEN SPRAYER, Preschool Room131	0.71	NO		Routine Control Measures Only	N/A	N/A
SAMPLING DATE			12/20/2019				1/28/2020	
RESULTS DATE			1/3/2020				1/30/2020	
DRINKING	CNIC26-138-WF 1st Draw	WATER FOUNTAIN (BUBBLER), OUTSIDE132 (Labeled 138 on results)	10.7	NO	3.1	Tested under CNIC lead action level of 15 ppb, not retested	N/A	N/A
DRINKING	CNIC26-132-WF 1st Draw	WATER FOUNTAIN (BUBBLER), OUTSIDE 139 (Labeled 132 on results)	45.4	YES	8.5	Fountain properly flushed	3.2	3.4

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS (Threshold of 15 ppb)			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Follow up Flush [(collected 30 seconds after First Draw (ppb))]	Description	Recommended Level = 15ppb	
							First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/6/2019			6/25/2019		
RESULTS DATE			4/16/2019			7/1/2019		
COOKING	WR-26-PSH132-KSP-FD 1st Draw	KITCHEN SPRAYER, Preschool Room132	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH133-KSP-FD 1st Draw	KITCHEN SPRAYER, Preschool Room133	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH134-KSP-FD 1st Draw	KITCHEN SPRAYER, Preschool Room134	0.69	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-PSH135-KSP-FD 1st Draw	KITCHEN SPRAYER, Preschool Room135	0.71	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-TOD137-KSP-FD 1st Draw	KITCHEN SPRAYER, Toddler Room137	0.84	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-TOD138-KSP-FD 1st Draw	KITCHEN SPRAYER, Toddler Room138	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-TOD139-KSP-FD 1st Draw	KITCHEN SPRAYER, Toddler Room139	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-TOD140-KSP-FD 1st Draw	KITCHEN SPRAYER, Toddler Room140	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-TOD141-KSP-FD 1st Draw	KITCHEN SPRAYER, Toddler Room141	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-K142-KA-FD 1st Draw	KITCHEN SINK FOR FOOD PREP -A, Kitchen142	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-K142-KB-FD 1st Draw	KITCHEN SINK FOR FOOD PREP -B, Kitchen142	non-detect	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-K142-KSPA-FD 1st Draw	KITCHEN SPRAYER -A, Kitchen142	12	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-K142-KSPB-FD 1st Draw	KITCHEN SPRAYER- B, Kitchen142	7.3	NO		Routine Control Measures Only	N/A	N/A
COOKING	WR-26-INF111-K-FD 2nd Draw	KITCHEN SINK FOR FOOD PREP, Infant Room111	non-detect	NO				
WASHING	WR-26-INF111-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room111	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-INF112-HHW-FD 1st Draw	HIGH HAND WASHING (adults) DIAPER CHANGING CENTER, Infant Roo	m non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-INF113-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room113	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-INF114-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room114	0.92	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-INF115-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room115	5.2	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH117-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Pre-Toddler117	1.2	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH117-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Pre-Toddler117	1.1	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH117-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Pre-Toddler117	1.3	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH118-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Pre-Toddler118	1.2	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH118-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Pre-Toddler118	1.5	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH118-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Pre-Toddler118	1.9	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH119-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Pre-Toddler119	1.9	NO		Routine Control Measures Only	N/A	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS (Threshold of 15 ppb)			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Follow up Flush [(collected 30 seconds after First Draw (ppb))]	Description	Recommended Level = 15ppb	
							First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/6/2019			6/25/2019		
RESULTS DATE			4/16/2019			7/1/2019		
WASHING	WR-26-PSH119-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth)A, Pre-Toddler119	1.4	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH119-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth)B, Pre-Toddler119	0.93	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH120-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Pre-Toddler120	2.4	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH120-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Pre-Toddler120	1.4	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH120-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Pre-Toddler120	1.1	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH121-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Pre-Toddler121	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH121-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (YOUTH)A, Pre-Toddler121	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH121-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth)B, Pre-Toddler121	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH122-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Pre-Toddler122	0.87	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH122-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Pre-Toddler122	0.86	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH122-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Pre-Toddler122	0.94	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-Bath124-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Bathroom Faucets124	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-Bath125-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Bathroom Faucets125	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-Bath126-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Bathroom Faucets126	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH131-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room131	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH131-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Preschool Room131	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH131-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Preschool Room131	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH132-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room132	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH132-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Preschool Room132	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH132-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Preschool Room132	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH133-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room133	0.8	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH133-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Preschool Room133	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH133-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Preschool Room133	0.59	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH134-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room134	1.6	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH134-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Preschool Room134	1.1	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH134-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Preschool Room134	0.99	NO		Routine Control Measures Only	N/A	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS (Threshold of 15 ppb)			CORRECTIVE ACTIONS	POST REMEDIATION SAMPLING RESULTS	
CATEGORY	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Follow up Flush [(collected 30 seconds after First Draw (ppb))]	Description	Recommended Level = 15ppb	
							First Draw (ppb)	Follow up Flush - Collected 30 seconds after First Draw Sampling (ppb)
SAMPLING DATE			4/6/2019				6/25/2019	
RESULTS DATE			4/16/2019				7/1/2019	
WASHING	WR-26-PSH135-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room135	1.5	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH135-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth)A, Preschool Room135	1.5	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-PSH135-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth)B, Preschool Room135	1.5	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD137-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room137	1	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD137-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Toddler Room137	0.68	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD137-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Toddler Room137	1.8	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD138-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room138	2.2	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD138-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Toddler Room138	1.3	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD138-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Toddler Room138	1.1	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD139-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room139	2.4	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD139-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Toddler Room139	1.4	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD139-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Toddler Room139	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD140-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room140	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD140-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Toddler Room140	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD140-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Toddler Room140	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD141-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room141	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD141-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Toddler Room141	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-TOD141-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Toddler Room141	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-K142-HHWA-FD 1st Draw	HIGH HAND WASHING (adults) A, Kitchen142	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-K142-HHWA-FD 1st Draw	HIGH HAND WASHING (adults) B, Kitchen142	non-detect	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-K142-HHWC-FD 1st Draw	HIGH HAND WASHING (adults) C, Kitchen142	0.71	NO		Routine Control Measures Only	N/A	N/A
WASHING	WR-26-K142-HHWD-FD 1st Draw	HIGH HAND WASHING (adults) D, Kitchen142	0.81	NO		Routine Control Measures Only	N/A	N/A

Notes:

¹ Affected outlets were immediately secured after receiving verbal communication from the lab on results exceeding the recommended level of 15ppb.

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
			Lead Screening Level of 15ppb		
CATEGORY	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE			4/6/2019		
RESULTS DATE			4/16/2019		
COOKING	WR-62-INF324-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room324	non-detect	NO	N/A
WASHING	WR-62-INF304-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room304	non-detect	NO	N/A
WASHING	WR-62-Bath305-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-A, Bathroom Faucets305	1	NO	N/A
WASHING	WR-62-Bath305-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-B, Bathroom Faucets305	non-detect	NO	N/A
WASHING	WR-62-TL307-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Teacher's LoungeB307	non-detect	NO	N/A
WASHING	WR-62-Bath320-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Bathroom FaucetsB320	0.66	NO	N/A
WASHING	WR-62-INF322-HHW-FD 1st Draw	HIGH HAND WASHING (adults) DIAPER CHANGING STATION, Infant Room322	non-detect	NO	N/A
WASHING	WR-62-INF323-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room323	3.7	NO	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
CATEGORY	SAMPLE ID	Outlet Description	Lead Screening Level of 15ppb		
			First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE			4/6/2019		
RESULTS DATE			4/16/2019		
DRINKING	WR-87-HLWY-HIGH-114-115-WFC-FD 1st Draw	WATER FOUNTAIN (COOLER), HALLWAY114 /115	non-detect	NO	N/A
DRINKING	WR-87-TOD142-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Toddler Room142	non-detect	NO	N/A
DRINKING	WR-87-OUT142-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Toddler Room142	non-detect	NO	N/A
DRINKING	WR-87-TOD143-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Toddler Room143	non-detect	NO	N/A
DRINKING	WR-87-TOD144-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Toddler Room144	non-detect	NO	N/A
DRINKING	WR-87-TOD145-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Toddler Room145	non-detect	NO	N/A
DRINKING	WR-87-PSH146-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Preschool Room146	non-detect	NO	N/A
DRINKING	WR-87-PSH147-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Preschool Room147	non-detect	NO	N/A
DRINKING	WR-87-OUT147-WF-FD 1st Draw	WATER FOUNTAIN (BUBBLER), OUTSIDE143	non-detect	NO	N/A
DRINKING	WR-87-PSH148-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Preschool Room148	non-detect	NO	N/A
DRINKING	WR-87-PSH149-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), Preschool Room149	non-detect	NO	N/A
DRINKING	WR-87-HLWY-LOW-114-115-WFC-FD 1st Draw	WATER FOUNTAIN (COOLER), HALLWAY114 /115	non-detect	NO	N/A
COOKING	WR-87-INF120-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room120	non-detect	NO	N/A
COOKING	WR-87-INF121-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room121	non-detect	NO	N/A
COOKING	WR-87-INF122-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room122	non-detect	NO	N/A
COOKING	WR-87-INF123-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room123	non-detect	NO	N/A
COOKING	WR-87-INF124-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room124	non-detect	NO	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
CATEGORY	SAMPLE ID	Outlet Description	Lead Screening Level of 15ppb		
			First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE RESULTS DATE			4/6/2019		
			4/16/2019		
COOKING	WR-87-K125-KA-FD 1st Draw	KITCHEN SINK FOR FOOD PREP-A, Kitchen125	non-detect	NO	N/A
COOKING	WR-87-K125-KB-FD 1st Draw	KITCHEN SINK FOR FOOD PREP-B, Kitchen125	non-detect	NO	N/A
COOKING	WR-87-K125-KC-FD 1st Draw	KITCHEN SINK FOR FOOD PREP-C, Kitchen125	non-detect	NO	N/A
COOKING	WR-87-K125-KSPA-FD 1st Draw	KITCHEN SPRAYER-A, Kitchen125	non-detect	NO	N/A
COOKING	WR-87-K125-KE-FD 1st Draw	KITCHEN SINK FOR FOOD PREP-E, Kitchen125	non-detect	NO	N/A
COOKING	WR-87-K125-KSPB-FD 1st Draw	KITCHEN SPRAYER-B, Kitchen125	non-detect	NO	N/A
COOKING	WR-87-INF132-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room132	0.79	NO	N/A
COOKING	WR-87-INF133-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room133	non-detect	NO	N/A
COOKING	WR-87-INF134-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room134	non-detect	NO	N/A
COOKING	WR-87-INF135-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Infant Room135	non-detect	NO	N/A
COOKING	WR-87-INF136-KB-FD 1st Draw	KITCHEN SINK FOR FOOD PREP-B, Infant Room136	non-detect	NO	N/A
COOKING	WR-87-PSH137-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room137	non-detect	NO	N/A
COOKING	WR-87-PSH138-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room138	non-detect	NO	N/A
COOKING	WR-87-PSH139-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room139	non-detect	NO	N/A
COOKING	WR-87-PSH141-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room141	non-detect	NO	N/A
COOKING	WR-87-TOD142-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Toddler Room142	non-detect	NO	N/A
COOKING	WR-87-TOD143-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Toddler Room143	non-detect	NO	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
CATEGORY	SAMPLE ID	Outlet Description	Lead Screening Level of 15ppb		
			First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE RESULTS DATE			4/6/2019		
			4/16/2019		
COOKING	WR-87-TOD144-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Toddler Room144	non-detect	NO	N/A
COOKING	WR-87-TOD145-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Toddler Room145	non-detect	NO	N/A
COOKING	WR-87-PSH146-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room146	non-detect	NO	N/A
COOKING	WR-87-PSH147-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room147	non-detect	NO	N/A
COOKING	WR-87-PSH148-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room148	non-detect	NO	N/A
COOKING	WR-87-PSH149-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room149	non-detect	NO	N/A
COOKING	WR-87-PSH150-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room150	non-detect	NO	N/A
COOKING	WR-87-PSH151-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room151	non-detect	NO	N/A
COOKING	WR-87-140-K-FD 1st Draw	KITCHEN SINK FOR FOOD PREP, Preschool Room140	non-detect	NO	N/A
WASHING	WR-87-TL106-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Teacher's Lounge106	non-detect	NO	N/A
WASHING	WR-87-Bath113-HHWA-FD 1st Draw	HIGH HAND WASHING (adults)A, Bathroom Faucets113	non-detect	NO	N/A
WASHING	WR-87-Bath114-HHWA-FD 1st Draw	HIGH HAND WASHING (adults)B, Bathroom Faucets114	non-detect	NO	N/A
WASHING	WR-87-Bath115-HHWC-FD 1st Draw	HIGH HAND WASHING (adults)C, Bathroom Faucets115	non-detect	NO	N/A
WASHING	WR-87-INF120-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room120	non-detect	NO	N/A
WASHING	WR-87-INF120-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room120	non-detect	NO	N/A
WASHING	WR-87-INF121-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room121	non-detect	NO	N/A
WASHING	WR-87-INF121-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room121	3.1	NO	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
CATEGORY	SAMPLE ID	Outlet Description	Lead Screening Level of 15ppb		
			First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE			4/6/2019		
RESULTS DATE			4/16/2019		
WASHING	WR-87-INF122-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room122	non-detect	NO	N/A
WASHING	WR-87-INF122-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room122	3.6	NO	N/A
WASHING	WR-87-INF123-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room123	non-detect	NO	N/A
WASHING	WR-87-INF123-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room123	0.94	NO	N/A
WASHING	WR-87-INF124-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room124	non-detect	NO	N/A
WASHING	WR-87-INF124-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room124	3.3	NO	N/A
WASHING	WR-87-K125-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Utility Sinks125	non-detect	NO	N/A
WASHING	WR-87-SHR127-HHWA-FD 1st Draw	HIGH HAND WASHING (adults) HAND SINK-A, SHOWER / TUB127	non-detect	NO	N/A
WASHING	WR-87-INF132-HHW-FD 1st Draw	HIGH HAND WASHING (adults) , Infant Room132	0.56	NO	N/A
WASHING	WR-87-INF132-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room132	2.2	NO	N/A
WASHING	WR-87-INF133-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room133	non-detect	NO	N/A
WASHING	WR-87-INF133-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room133	9.7	NO	N/A
WASHING	WR-87-INF134-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room134	non-detect	NO	N/A
WASHING	WR-87-INF134-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room134	2.5	NO	N/A
WASHING	WR-87-INF135-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room135	non-detect	NO	N/A
WASHING	WR-87-INF135-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room135	4	NO	N/A
WASHING	WR-87-INF136-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room136	non-detect	NO	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
CATEGORY	SAMPLE ID	Outlet Description	Lead Screening Level of 15ppb		
			First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE			4/6/2019		
RESULTS DATE			4/16/2019		
WASHING	WR-87-INF136-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Infant Room136	3	NO	N/A
WASHING	WR-87-PSH137-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room137	non-detect	NO	N/A
WASHING	WR-87-PSH137-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Preschool Room137	non-detect	NO	N/A
WASHING	WR-87-PSH138-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room138	non-detect	NO	N/A
WASHING	WR-87-PSH138-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Preschool Room138	non-detect	NO	N/A
WASHING	WR-87-PSH139-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room139	non-detect	NO	N/A
WASHING	WR-87-PSH139-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Preschool Room139	non-detect	NO	N/A
WASHING	WR-87-PSH141-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room141	non-detect	NO	N/A
WASHING	WR-87-PSH141-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Preschool Room141	non-detect	NO	N/A
WASHING	WR-87-TOD142-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room142	non-detect	NO	N/A
WASHING	WR-87-TOD142-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-A, Toddler Room142	non-detect	NO	N/A
WASHING	WR-87-TOD142-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-B, Toddler Room142	non-detect	NO	N/A
WASHING	WR-87-TOD142-LHWC-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-C, Toddler Room142	non-detect	NO	N/A
WASHING	WR-87-TOD143-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room143	non-detect	NO	N/A
WASHING	WR-87-TOD143-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-A, Toddler Room143	non-detect	NO	N/A
WASHING	WR-87-TOD143-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-B, Toddler Room143	non-detect	NO	N/A
WASHING	WR-87-TOD143-LHWC-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-C, Toddler Room143	non-detect	NO	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
CATEGORY	SAMPLE ID	Outlet Description	Lead Screening Level of 15ppb		
			First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE			4/6/2019		
RESULTS DATE			4/16/2019		
WASHING	WR-87-TOD144-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room144	non-detect	NO	N/A
WASHING	WR-87-TOD144-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-A, Toddler Room144	non-detect	NO	N/A
WASHING	WR-87-TOD144-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-B, Toddler Room144	non-detect	NO	N/A
WASHING	WR-87-TOD144-LHWC-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-C, Toddler Room144	non-detect	NO	N/A
WASHING	WR-87-TOD145-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Toddler Room145	non-detect	NO	N/A
WASHING	WR-87-TOD145-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-A, Toddler Room145	non-detect	NO	N/A
WASHING	WR-87-TOD145-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-B, Toddler Room145	non-detect	NO	N/A
WASHING	WR-87-TOD145-LHWC-FD 1st Draw	LOW HAND WASHING FAUCET (youth)-C, Toddler Room145	non-detect	NO	N/A
WASHING	WR-87-PSH146-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room146	non-detect	NO	N/A
WASHING	WR-87-PSH146-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Preschool Room146	non-detect	NO	N/A
WASHING	WR-87-PSH146-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Preschool Room146	non-detect	NO	N/A
WASHING	WR-87-PSH146-LHWC-FD 1st Draw	LOW HAND WASHING FAUCET (youth) C, Preschool Room146	non-detect	NO	N/A
WASHING	WR-87-PSH147-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room147	non-detect	NO	N/A
WASHING	WR-87-PSH147-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Preschool Room147	non-detect	NO	N/A
WASHING	WR-87-PSH147-LHWB-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Preschool Room147	non-detect	NO	N/A
WASHING	WR-87-PSH147-LHWC-FD 1st Draw	LOW HAND WASHING FAUCET (youth) C, Preschool Room147	non-detect	NO	N/A
WASHING	WR-87-PSH148-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room148	non-detect	NO	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
CATEGORY	SAMPLE ID	Outlet Description	Lead Screening Level of 15ppb		
			First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE RESULTS DATE			4/6/2019		
			4/16/2019		
WASHING	WR-87-PSH148-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Preschool Room148	non-detect	NO	N/A
WASHING	WR-87-PSH148-LHWP-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Preschool Room148	non-detect	NO	N/A
WASHING	WR-87-PSH148-LHWC-FD 1st Draw	LOW HAND WASHING FAUCET (youth) C, Preschool Room148	non-detect	NO	N/A
WASHING	WR-87-PSH149-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room149	non-detect	NO	N/A
WASHING	WR-87-PSH149-LHWA-FD 1st Draw	LOW HAND WASHING FAUCET (youth) A, Preschool Room149	non-detect	NO	N/A
WASHING	WR-87-PSH149-LHWP-FD 1st Draw	LOW HAND WASHING FAUCET (youth) B, Preschool Room149	non-detect	NO	N/A
WASHING	WR-87-PSH149-LHWC-FD 1st Draw	LOW HAND WASHING FAUCET (youth) C, Preschool Room149	non-detect	NO	N/A
WASHING	WR-87-PSH150-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room150	non-detect	NO	N/A
WASHING	WR-87-PSH150-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Preschool Room150	non-detect	NO	N/A
WASHING	WR-87-PSH151-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room151	non-detect	NO	N/A
WASHING	WR-87-PSH151-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Preschool Room151	non-detect	NO	N/A
WASHING	WR-87-140-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Preschool Room140	non-detect	NO	N/A
WASHING	WR-87-140-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Preschool Room140	non-detect	NO	N/A

SAMPLING LOCATION DESCRIPTION			INITIAL SAMPLING RESULTS		
			Lead Screening Level of 15ppb		
CATEGORY	SAMPLE ID	Outlet Description	First Draw (ppb)	Retest required?	Follow up Flush [[collected 30 seconds after First Draw (ppb)]]
SAMPLING DATE			4/6/2019		
RESULTS DATE			4/15/2019		
DRINKING	WR-88-OUT207-WFB-FD 1st Draw	WATER FOUNTAIN (BUBBLER), OUTSIDE207	0.69	NO	N/A
COOKING	WR-88-K205-KA-FD 1st Draw	KITCHEN SINK FOR FOOD PREP-A, Kitchen205	0.72	NO	N/A
COOKING	WR-88-K205-KB-FD 1st Draw	KITCHEN SINK FOR FOOD PREP-B, Kitchen205	non-detect	NO	N/A
WASHING	WR-88-Bath204-HWCOMB-FD 1st Draw	HANDWASHING FAUCET (COMBINATION), Bathroom Faucets 204	non-detect	NO	N/A
WASHING	WR-88-Bath206-LHW-FD 1st Draw	LOW HAND WASHING FAUCET (youth), Bathroom Faucets206	0.67	NO	N/A
WASHING	WR-88-Bath208-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Bathroom Faucets208	non-detect	NO	N/A
WASHING	WR-88-INF214-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room214	0.73	NO	N/A
WASHING	WR-88-INF215-HHW-FD 1st Draw	HIGH HAND WASHING (adults), Infant Room215	non-detect	NO	N/A